



Antiscalant dosage

In order to avoid scaling in the spiral, it is necessary to check the hardness of the water and correct it, if necessary, by adding MC 210.

In the following table you can see how many ml of fluid must be added.

		AMOUNT OF ADDED WATER (IN LITRES)												
NUMBER OF DEGREES THAT THE HARDNESS MUST BE REDUCED		1300	1200	1100	1000	900	800	700	600	500	400	300	200	100
	25	618	570	523	475	428	380	333	285	238	190	143	95	48
	24	593	547	502	456	410	365	319	274	228	182	137	91	46
	23	568	524	481	437	393	350	306	262	219	175	131	87	44
	22	543	502	460	418	376	334	293	251	209	167	125	84	42
	21	519	479	439	399	359	319	279	239	200	160	120	80	40
	20	494	456	418	380	342	304	266	228	190	152	114	76	38
	19	469	433	397	361	325	289	253	217	181	144	108	72	36
	18	445	410	376	342	308	274	239	205	171	137	103	68	34
	17	420	388	355	323	291	258	226	194	162	129	97	65	32
	16	35	365	334	304	274	243	213	182	152	122	91	61	30
	15	371	342	314	85	257	228	200	171	143	114	86	57	29
	14	346	319	293	266	239	213	186	160	133	106	80	53	27
	13	321	296	272	247	222	198	173	148	124	99	74	49	25
	12	296	274	251	228	205	182	160	137	114	91	68	46	23
	11	272	251	230	209	188	167	146	125	105	84	63	42	21
10	247	228	209	190	171	152	133	114	95	76	57	38	19	
9	222	205	188	171	154	137	120	103	86	68	51	34	17	
8	198	182	167	152	137	122	106	91	76	61	46	30	15	
7	173	160	146	133	120	106	93	80	67	53	40	27	13	
6	148	137	125	114	103	91	80	68	57	46	34	23	11	
5	124	114	105	95	86	76	67	57	48	38	29	19	10	
4	99	91	84	76	68	61	53	46	38	30	23	15	8	
3	74	68	63	57	51	46	40	34	29	23	17	11	6	
2	49	46	42	38	34	30	27	23	19	15	11	8	4	
1	25	23	21	19	17	15	13	11	10	8	6	4	2	